

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY

CCR CERTIFICATION
CALENDAR YEAR 2014

Glendale Utility District

Public Water Supply Name

0180007

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- ☐ Advertisement in local paper (attach copy of advertisement)
☒ On water bills (attach copy of bill)
☒ Email message (MUST Email the message to the address below)
☒ Other Posted at office - 2805 Glendale Ave.

Date(s) customers were informed: 5/29/15 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used on water bills

Date Mailed/Distributed: 5/29/15

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: / /

- ☐ As a URL (Provide URL)
☐ As an attachment
☐ As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: / /

CCR was posted in public places. *(Attach list of locations)*

Date Posted: / /

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

www.glendaleutilitydisrict.ruralwaterusa.com/water-quality-report

CERTIFICATION

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Janice Strack - Office Manager
Name/Title (President, Mayor, Owner, etc.)

5/29/15
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601) 576-7800

May be emailed to:
water.reports@msdh.ms.gov

2015 JUN -1 AM 11: 27

We posted the CCR report on the front door and payment window at the Glendale Utility District's office on May 29, 2015.

The CCR was posted on our website on May 29, 2015 and notified all customers with a message on the back of our billing cards to visit our website and view the CCR or request a hard copy at our office. These bills were mailed May 29, 2015.

2015 JUN -1 AM 11: 27

2014 Annual Drinking Water Quality Report
Glendale Utility District
PWS#: 0180007
May 2015

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from three wells drawing from the Catahoula Formation and Lower Catahoula Formation Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Glendale Utility District have received a lower to moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact David Draughn at 601.583.0647. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Thursday of each month at 5:00 PM at the Glendale Utility -2805 Glendale Ave., Hattiesburg, MS 39401.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2014	.0056	.0034 - .0056	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014	4	2.4 - 4	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2011/13*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

16. Fluoride	N	2014	.167	.147 - .167	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011/13*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2014	2	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014	4.48	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2014	1.1	.8 – 1.92	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2014.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", our system is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 8. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 78%.

The Glendale Utility District works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. This report will not be mailed to customers. A copy will be available in the office.

GLENDAL UTILITY DISTRICT
(601) 583-0647
2805 GLENDALE AVENUE
HATTIESBURG, MISSISSIPPI 39401

RETURN SERVICE
REQUESTED

READ DATE	CODE
05/14/15	01

FIRST-CLASS MAIL
PRESORTED
U.S. POSTAGE PAID
HATTIESBURG, MISS.
PERMIT NO. 66

SRVC	NEW RDG	LAST RDG	USED	CHARGES
WAT	185030	180790	4240	20.96

PLEASE BRING THIS ENTIRE BILL TO OFFICE
OR MAIL THIS STUB WITH YOUR PAYMENT

SRVC ADDR	496 EATONVILLE RD		
ACCOUNT #	0393	ROUTE	01
NOW DUE	DATE DUE	REMIT AFTER DUE DATE	
20.96	06/15/15	23.06	

CCR REPORT ON BACK OF CARD
FIRE DEPT. DONATON \$5

ROUTE	METER #	NOW DUE	PAY EARLY SAVE THIS	REMIT AFTER DUE DATE
01	393	20.96	2.10	23.06
ACCT	0393			

ORVILLE COOLEY
496 EATONVILLE ROAD
HATTIESBURG, MS 39401

2015 JUN -1 AM 11:27

GLENDAL UTILITY DISTRICT
(601) 583-0647
2805 GLENDALE AVENUE
HATTIESBURG, MISSISSIPPI 39401

RETURN SERVICE
REQUESTED

READ DATE	CODE
05/14/15	01

FIRST-CLASS MAIL
PRESORTED
U.S. POSTAGE PAID
HATTIESBURG, MISS.
PERMIT NO. 66

SRVC	NEW RDG	LAST RDG	USED	CHARGES
WAT	636350	633100	3250	17.00
L/C				1.48
CREDIT				-1.48

PLEASE BRING THIS ENTIRE BILL TO OFFICE
OR MAIL THIS STUB WITH YOUR PAYMENT

SRVC ADDR	17 BROCK RD		
ACCOUNT #	0394	ROUTE	01
NOW DUE	DATE DUE	REMIT AFTER DUE DATE	
17.00	06/15/15	18.70	

CCR REPORT ON BACK OF CARD
FIRE DEPT. DONATON \$5

ROUTE	METER #	NOW DUE	PAY EARLY SAVE THIS	REMIT AFTER DUE DATE
01	394	17.00	1.70	18.70
ACCT	0394			

LIBBY DOUGLAS
17 BROCK RD.
HATTIESBURG, MS 39401

2015 JUN -1 AM 11:27

GLENDAL UTILITY DISTRICT
(601) 583-0647
2805 GLENDALE AVENUE
HATTIESBURG, MISSISSIPPI 39401

RETURN SERVICE
REQUESTED

READ DATE	CODE
05/14/15	01

FIRST-CLASS MAIL
PRESORTED
U.S. POSTAGE PAID
HATTIESBURG, MISS.
PERMIT NO. 66

SRVC	NEW RDG	LAST RDG	USED	CHARGES
WAT	580940	575330	5610	26.44

PLEASE BRING THIS ENTIRE BILL TO OFFICE
OR MAIL THIS STUB WITH YOUR PAYMENT

SRVC ADDR	491 EATONVILLE RD		
ACCOUNT #	0392	ROUTE	01
NOW DUE	DATE DUE	REMIT AFTER DUE DATE	
26.44	06/15/15	29.08	

CCR REPORT ON BACK OF CARD
FIRE DEPT. DONATON \$5

ROUTE	METER #	NOW DUE	PAY EARLY SAVE THIS	REMIT AFTER DUE DATE
01	392	26.44	2.64	29.08
ACCT	0392			

VIOLA PACE
491 EATONVILLE RD.
HATTIESBURG, MS 39401

2015 JUN -1 AM 11:27

Important information about your drinking water is available in the 2014 Consumer Confidence Report @ glendaleutilitydistrict.ruralwaterusa.com /water-quality-report

You may request a hard copy by checking this box ☐ or by calling our office a 601-583-0647.

To Receive email or text alerts on emergencies or boil water notices please provide the following information and return this portion of your bill so that we may enter it into our system or visit our website and enter your information via the "ALERTS" tab. Thank you.

Email address _____

Cell phone# _____

Phone service provider _____

Important information about your drinking water is available in the 2014 Consumer Confidence Report @ glendaleutilitydistrict.ruralwaterusa.com /water-quality-report

You may request a hard copy by checking this box ☐ or by calling our office a 601-583-0647.

To Receive email or text alerts on emergencies or boil water notices please provide the following information and return this portion of your bill so that we may enter it into our system or visit our website and enter your information via the "ALERTS" tab. Thank you.

Email address _____

Cell phone# _____

Phone service provider _____

Important information about your drinking water is available in the 2014 Consumer Confidence Report @ glendaleutilitydistrict.ruralwaterusa.com /water-quality-report

You may request a hard copy by checking this box ☐ or by calling our office a 601-583-0647.

To Receive email or text alerts on emergencies or boil water notices please provide the following information and return this portion of your bill so that we may enter it into our system or visit our website and enter your information via the "ALERTS" tab. Thank you.

Email address _____

Cell phone# _____

Phone service provider _____

2015 JUN -1 AM 11:27